




BASE4
9858 GLADES ROAD, #237
BOCA RATON, FLORIDA 33434
720.727.4444 www.base-4.com

SEAL



ISSUE:

Issued for Permit
08.05.2016

PROJECT: 16-018

Hampton Inn & Suites

New Stanton, PA 15672

OWNER:

Stanton Hospitality LLC

52 Blueberry Lane,
Grove City, PA 16127

[illegible]

DATE 2016.08.05

DRAWN BY HAB

CHECKED BY GWV

SCALE AS NOTED

PROJECT NO. B4-67-1603

SHEET NAME

ROOF MECHANICAL PLAN

SHEET NO.

M204

01 ROOF MECHANICAL PLAN
SCALE: 3/32" = 1'-0"

KEY NOTES:

- ① 72X36 LOUVER WITH NORMALLY CLOSED, U.L. LISTED SMOKE DAMPER FOR ELEVATOR SHAFT VENT. DAMPER SHALL OPEN UPON ACTIVATION OF FIRE ALARM SYSTEM.
- ② INSULATE Q/A DUCTS TO A MINIMUM R-VALUE OF 8.0.
- ③ MECHANICAL CONTRACTOR TO INSTALL DUCT SMOKE DETECTOR.

[illegible]

DATE 2016.08.05

DRAWN BY HAB

CHECKED BY GWV

SCALE AS NOTED

PROJECT NO. B4-67-1603

SHEET NAME

ROOF MECHANICAL PLAN

SHEET NO.

M204